

Elbow Grease Enterprises, LLC Safety Audit Form

Project:	Auditor:		Date:
Inspection Item	Yes	No	Notes
STAIRS AND STAIRWAYS			
Do standard stair rails or handrails on all stairways have at least four risers?	<input type="checkbox"/>	<input type="checkbox"/>	
Are all stairways at least 22 inches (55.88 centimeters) wide?	<input type="checkbox"/>	<input type="checkbox"/>	
Do stairs have landing platforms not less than 30 inches (76.20 centimeters) in the direction of travel and extend 22 inches (55.88 centimeters) in width at every 12 feet (3.6576 meters) or less of vertical rise?	<input type="checkbox"/>	<input type="checkbox"/>	
Do stairs angle no more than 50 and no less than 30 degrees?	<input type="checkbox"/>	<input type="checkbox"/>	
Are stairs of hollow-pan type treads and landings filled to the top edge of the pan with solid material?	<input type="checkbox"/>	<input type="checkbox"/>	
Are step risers on stairs uniform from top to bottom?	<input type="checkbox"/>	<input type="checkbox"/>	
Are steps slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>	
Are stairway handrails located between 30 inches (76.20 centimeters) and 34 inches (86.36 centimeters) above the leading edge of stair treads?	<input type="checkbox"/>	<input type="checkbox"/>	
Do stairway handrails have at least 3 inches (7.62 centimeters) of clearance between the handrails and the wall or surface they are mounted on?	<input type="checkbox"/>	<input type="checkbox"/>	
Where doors or gates open directly on a stairway, is a platform provided so the swing of the door does not reduce the width of the platform to less than 21 inches (53.34 centimeters)?	<input type="checkbox"/>	<input type="checkbox"/>	
Are stairway handrails capable of withstanding a load of 200 pounds (90.7 kilograms), applied within 2 inches (5.08 centimeters) of the top edge in any downward or outward direction?	<input type="checkbox"/>	<input type="checkbox"/>	
Where stairs or stairways exit directly into any area where vehicles may be operated, are adequate barriers and warnings provided to prevent employees from stepping into the path of traffic?	<input type="checkbox"/>	<input type="checkbox"/>	
Do stairway landings have a dimension measured in the direction of travel at least equal to the width of the stairway?	<input type="checkbox"/>	<input type="checkbox"/>	
Is the vertical distance between stairway landings limited to 12 feet (3.6576 meters) or less?	<input type="checkbox"/>	<input type="checkbox"/>	